

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 4485-1427:100 Page 1 of 1

CATEGORY: Opening Protection/Firestopping

LISTEE: NPC Sealants Corp., 1208 S. 8th Avenue, Maywood, IL 60153
Contact: Steve Stefely (708) 681-1040

DESIGN: NPC 50 FIRESTOP SEALANT for lightweight concrete floor/wall slabs containing through penetration firestop systems.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation and UL label.

APPROVAL: Listed as 2 and 3 Hr. rating firestopping. Approved as follow: System Nos. CAJ-1141 (3 Hr.), CAJ-1143 (3 Hr.) and CAJ-2058 (2 Hr.). Refer to UL Fire Resistance Directory for detailed construction.

07-27-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 17, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager